

Table 2

<u>From</u>	<u>To Septic Tank Or Equivalent</u>	<u>To Absorption System</u>
Wells (includes neighboring wells)	50	100
Property lines	10	10
Building Foundation (without foundation drains)	5	10
Building Foundation (with foundation drains)	5	25
Potable Water Pipes	25	25
Septic Tank		10
Stream or Surface		
Body of Water if percolation rate \geq 5 (including seasonal and intermittent)	50	50
Body of Water if percolation rate $<$ 5 (including seasonal and intermittent)	50	100

b. Location. Absorption systems shall not be located beneath buildings, parking lots, roadways or other similarly compacted areas.

Section 20. Site Suitability

a. Soil Exploration. Soil exploration to a minimum depth of four feet below the bottom of the proposed absorption system shall be made to provide information on subsoil conditions.

b. Soil Evaluation.

(1) No less than three percolation tests shall be run in the proposed absorption system location. The percolation tests shall be performed in accordance with Appendix A. The type of soil encountered at the percolation test location shall be specified.

(2) An evaluation of the soil texture by a person experienced in soils classification, may be used to estimate the percolation rate, but at least one percolation test shall be performed.