

$$\frac{\text{Time Interval (minutes)}}{\text{Final Water Level Drop (inches)}}$$

If only three to five percolation tests are performed, the design percolation rate for the absorption system is the slowest rate from all the holes tested. If six or more percolation tests are performed, the design percolation rate for the absorption system is the average of all holes tested as determined by the above formula.